

ADDENDUM 2

Baseball Field Dugout Project

Bids Due: Thursday, May 1st at 1:00PM

1. What height backstop?

A minimum 30ft high backstop. The back stop is 40 feet wide.

2. How far are the backstop wings to extend before dropping to the 5'h?

The backstop wings should extend to match existing (40 ft. total) before dropping to 5' height

The home plate side wings are 5 feet high (yellow caps on top).

The away side fence wings are 12 feet high.

3. Are fences to include poly caps? If so what color?

The fence should include poly caps. For the dugout fence we would like navy or black poly caps and for the side fencing they should be yellow, to match the outfield fence poly cap.

4. Are foul poles to be included when connecting to outfield fence? If so, what spec?

Foul poles are already there and set. Nothing needed with them.

5. Please provide specifications for wall matting behind the plate.

ACM will provide the padding for the backstop. Contractor will only install.